

Filtration Test completed on Lakos Separator Model: eJPX-0080-V

The filter assembly was installed with test components defined as follows:

- 1) 3" turbine-type flow meter
- 2) 20 micron disc filter assembly
- 3) 2" pipe spool with sand-injection pump
- 4) Separator under test
- 5) 2" pipe spool
- 6) 20 micron disc filter assembly

Test Conditions: 130 US gpm, 12.9 psi loss

Media Sample	45-75 micron: 50 grams Media: Quartz, specific gravity: 2.6, Silicon Dioxide by Powder Technology Inc
Media Recovery	From downstream filters: 0.6 grams
Filter Efficiency	$49.4 / 50.0 = 98.8\%$

Test Date: October 19, 2012



Joe C. Oliphant
Hydraulics Lab Manager