



EXCEPT AS OTHERWISE PROVIDED BY CONTRACT, THIS DRAWING AND SPECIFICATIONS SHALL NOT BE REPRODUCED, COPIED OR USED AS THE BASIS FOR MANUFACTURE OR SALE OF WATER DISPENSER HEREIN WITHOUT THE EXPRESSED WRITTEN PERMISSION OF THE CLAUDE LAVAL CORPORATION, OR ITS ASSIGNEES.

REVISIONS			
ZONE	REV	DESCRIPTION	DATE

THIS DRAWING HAS BEEN GENERATED AND IS MAINTAINED BY A CAD SYSTEM. CHANGES SHALL ONLY BE INCORPORATED AS DIRECTED BY AN APPROVED ENGINEERING CHANGE ORDER (ECO). PAPER COPIES ARE UNCONTROLLED.

NOTES:

1. INLET & OUTLET IS 3/4" MPT.
2. MAXIMUM PRESSURE: 150 psi. (1034 kPa).
3. MAXIMUM TEMPERATURE: 180°F (82.2°C).
4. PRESSURE LOSS: 5.0-12.0 psid AT RATED FLOW.
5. RATED FLOW: 10-20 gpm (2.5-4.5 m³/hr).
6. APPROXIMATE DRY WEIGHT: 14 lbs. (6.4 kg.).



SUBMITTAL DRAWING

This drawing is submitted for special consideration only. Do not pre-plumb to these dimensions. Certified drawings available upon request.

UNLESS OTHERWISE SPECIFIED: DIMENSIONS ARE IN INCHES (mm) TOLERANCES ARE: FRACTIONS DECIMALS ANGLES ±1/4 .05 ±.01 ±1/4° DO NOT SCALE DRAWING		
MATERIAL CLASS P-1		

ENGINEERED FOR: STANDARD	APPROVALS	DATE
DRAWN R. JONES	5/23/93	
REMOVED SF	6/5/00	

LAKOS CLAUDE LAVAL CORP. 1366 N. CLOVIS AVE. FRESNO, CALIFORNIA 93727	TITLE ILB-0075, SEPARATOR, 3/4" NPT INLINE, CS
--	--