

3

 \square

		1		
		REVISION HISTORY		
ZONE REV		DESCRIPTION	DATE	APPROVED
				•

THIS DRAWING HAS BEEN GENERATED AND IS MAINTAINED BY A CAD SYSTEM. CHANGES SHALL ONLY BE INCORPORATED AS DIRECTED BY AN APPROVED ENGINEERING CHANGE ORDER (ECO). PAPER COPIES ARE UNCONTROLLED.

D

С

 \pm

15459

NOTES:

- 1. INLET IS 6" PIPE (150# ANSI FLANGED).
- 2. OUTLET IS 4" PIPE (GROOVED).
- 3. PURGE OUTLET IS 1-1/2" PIPE.
- 4. MAXIMUM PRESSURE: 150 psi (10.3 bar).
- 5. MAXIMUM TEMPERATURE: 100°F (37.8°C).
- 6. SPECIFIED FLOWRATE OF 525 gpm (119 m³/hr).
- NOTE: SYSTEM CAN RUN UP TO 600GPM (136 m³/hr)
- 7. FINISH: AS ASSEMBLED.
- 8. POWER REQUIREMENT: 460V, 3PH, 60Hz.
- 9. NEMA 4X MOTOR STARTER ENCLOSURE WITH SAFETY DISCONNECT AND H.O.A. SWITCH.
- 10. APPROXIMATE DRY WEIGHT: 1056 lbs (479 kg).
- 11. INLET/OUTLET VALVE KIT, MODEL TCV-0525 RECOMMENDED.
- 12. MINIMUM PIPE FROM TOWER BASIN TO TC SYSTEM IS 8" PIPE.
- 13. FLOODED SUCTION REQUIRED.

COMPONENT LIST:

- 1) ELECTRICAL CONTROL BOX 460V 60Hz W/120V TRANSFORMER.
- 2) SEPARATOR: HTH-0285-TC.
- ③ PUMP: 15 HP CENTRIFUGAL, 1750 rpm, 460V, 60Hz.
- (4) INLET/OUTLET PRESSURE GAUGES: 0-100 psi, GLYCERIN-FILLED.
- 5 PURGE EQUIPMENT: SRV-816.
- 6 DIFFERENTIAL PRESSURE INDICATOR:
- (AVAILABLE WITH DRY DRY CONTACT-MODEL DHE-15-S. ORDER SEPARATELY).

N	G	
ıtia plu	l mb	

2

	ERWISE SPECIFIE S ARE IN: INCHE S ARE:	
FRACTIONS	DECIMALS	AN
± 1/2"	.XX ± .01 .XXX ± .005	±

INLESS OTHERWISE SPECIFIED: DIMENSIONS ARE IN: INCHES [mm] OLERANCES ARE:	ENGINEERED FOR: 33272-1-10			A
RACTIONS DECIMALS ANGLES ± 1/2" .XX ± .01 ± 1/4° .XXX ± .005 .XXXX ± .0005	APPROVALS	DATE	WWW.LAKOS.COM	
DO NOT SCALE DRAWING	GMB/DLW	11/16/04	TBI-0525-SRV, TC SYSTEM,	
PER LAKOS SPEC	^{ENGR} HSK	1/3/05	SIDESTREAM HTH-0285, 460V 60HZ STD	
AS ASSEMBLED	MFG _	-	SIZE MODEL NO. DWG NO. 115459 B	
	WORK ORDER	QTY.	SCALE 1:12 EST. WT. 1056 lb SHEET 1 OF 1	

2