

THIS DRAWING HAS BEEN GENERATED AND IS MAINTAINED BY A CAD SYSTEM. CHANGES SHALL ONLY BE INCORPORATED AS DIRECTED BY AN APPROVED ENGINEERING CHANGE ORDER (ECO). PAPER COPIES ARE UNCONTROLLED.

D

С

154

6


 $\mathbf{O}$ 

## NOTES:

- 1. INLET IS 2" PIPE (NPT).
- 2. OUTLET IS 1-1/2" PIPE (GROOVED).
- PURGE OUTLET IS 3/4" PIPE. 3.
- MAXIMUM PRESSURE: 150 psi (10.3 bar). 4.
- MAXIMUM TEMPERATURE: 100°F (37.8°C). 5.
- SPECIFIED FLOWRATE OF 65 gpm (15 m<sup>3</sup>/hr). 6.
- FINISH: AS ASSEMBLED. 7.
- POWER REQUIREMENT: 460V, 3PH, 60Hz. 8.
- 9. NEMA 4X MOTOR STARTER ENCLOSURE WITH SAFETY DISCONNECT AND H.O.A. SWITCH.
- 10. APPROXIMATE DRY WEIGHT: 356 lbs (160 kg).
- 11. INLET/OUTLET VALVE KIT, MODEL TCV-0065 RECOMMENDED.
- 12. MINIMUM PIPE FROM TOWER BASIN TO TC SYSTEM IS 2-1/2" PIPE.
- 13. FLOODED SUCTION REQUIRED.

## COMPONENT LIST:

- (1) ELECTRICAL CONTROL BOX 460V 60Hz W/120V TRANSFORMER.
- (2) SEPARATOR: ILB-0150-TC.
- (3) PUMP: 3 HP CENTRIFUGAL, 3500 rpm, 460V, 60Hz.
- $(\overline{4})$  INLET/OUTLET PRESSURE GAUGES: 0-100 psi, GLYCERIN-FILLED.
- (5) PURGE EQUIPMENT: SRV-816.
- (6) DIFFERENTIAL PRESSURE INDICATOR: (AVAILABLE WITH DRY DRY CONTACT-
- MODEL DHE-15-S. ORDER SEPARATELY)
- (7) BASKET STRAINER



## FRONT VIEW PUMP & STRAINER

UNLESS OTHERWISE SPECIFIED:	ENGINEERED FOR:		A
DIMENSIONS ARE IN: INCHES [mm] TOLERANCES ARE: FRACTIONS DECIMALS ANGLES	STANDARD		
± 1/2" .XX ± .01 ± 1/4° .XXX ± .005 .XXX ± .005	APPROVALS	DATE	WWW.LAKOS.COM
DO NOT SCALE DRAWING	drawn SGF/A	DJ 5/25/05	TCI-0065-SRV, TC SYSTEM,
MATERIAL PER LAKOS SPEC	<sup>ENGR</sup> HSK	5/25/05	SWEEPER ILB-0150, 460V 60HZ STD
FINISH AS ASSEMBLED	MFG _	-	SIZE MODEL NO. DWG NO. 115/11/
	WORK ORDER	QTY.	C 115416 C   SCALE 1:8 EST. WT. 356 lb SHEET 1 OF 1
2	4	I	1



2