

Filtration Test completed on Lakos Separator Model: eHTX-0185-V

The filter assembly was installed with test components defined as follows:

- 1) 3" turbine-type flow meter
- 2) 20 micron disc filter assembly
- 3) 4" pipe spool with sand-injection pump
- 4) Separator under test
- 5) 4" pipe spool
- 6) 20 micron disc filter assembly

Test Conditions: 400 US gpm, 12.0 psi loss

Media Sample	45-75 micron: 75 grams Media: Quartz, specific gravity: 2.6, Silicon Dioxide by Powder Technology Inc
Media Recovery	From downstream filters: 3.2 grams
Filter Efficiency	$71.8 / 75.0 = 95.7\%$

Test Date: December 7, 2012



Joe C. Oliphant
Hydraulics Lab Manager